


Detex Corporation, 302 Detex Drive, New Braunfels, Texas 78130-3045 (830)629-2900 / 1-800-729-3839 / Fax (830)620-6711
 E-MAIL: detex@detex.com INTERNET: www.detex.com

WIRING INSTRUCTIONS FOR CS900/CS2900 SERIES REMOTE ALARMS

CS900 - DC Only (9V Battery) CS2900 - Externally Powered (w/Battery backup)



AC Adapter:
 P/N: 103985-1
 (CS2900 Only) Install wires to terminal block.
 Striped Wire is (+)

CS900 / CS2900 Terminal Block Table	
Functions	Description
Ext 9V DC (+) Striped wire	DC Power Supply (not supplied with CS900 products)
Ext 9V DC (-)	
Loop Monitor	To Open Loop security device
Loop Return	

Normally open contact.
 Closed contacts sound alarm.

Recommended Wire Sizes	
Wire Gauge	Maximum Length of Two Conductor Cable
22 AWG	50 Feet of twisted pair
20 AWG	250 Feet of twisted pair
18 AWG	1000 Feet of twisted pair

Press-In Anchors
 P/N: 102642-3
 Recommended drill size
 for anchors: 1/4" diameter
 NOTE: Also included are self-drilling screws

