



Input 9: Security Override

Continuous contact closure of this input triggers the operator to disable Input 2 / Activation 2. This is typically used for switching off an outside wall plate.

